

CITY OF MONTPELIER WATER SYSTEM-VT#5272
CONSUMER CONFIDENCE REPORT
Water Quality Report for Calendar Year 2016

This report is a snapshot of the quality of the water that we provided in 2016. Included are the details about where our water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. This report is designed to inform you about the quality water and services we deliver to you every day. For more information, please contact Thomas J. McArdle, Director of Public Works, or Kurt S. Motyka, PE, City Engineer, at 802.223.9508.

Water Source Information

The source of raw water prior to treatment is Berlin Pond, located in the town of Berlin. Berlin Pond, fed by streams and springs, is a 270-acre pond impounding 1.5 billion gallons of water. Raw water is transmitted via pipeline to the Water Filtration Facility to be treated for reduction or elimination of bacteria, viruses, parasites, color, taste, odor, turbidity, organic matter, iron and manganese.

The City of Montpelier has developed a Source Water Protection Plan for the Berlin Pond watershed area, approved by the Montpelier City Council on June 27, 2001, and by the Vermont Water Supply Division on September 8, 2001, that provides more information. This plan delineates a source protection area for our system and identifies potential and actual sources of contamination. The City is currently implementing the plan and reports annually to the State on our progress. Since recreational use was permitted on the Pond, modifications have been made to the Source Protection Plan, and the City had an engineering study conducted to examine the potential impacts on water quality. The City is currently negotiating with interested stakeholders on possible limited restrictions.

Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs). As water travels over the land's surface or through the ground, it dissolves naturally-occurring minerals. It also picks up substances resulting from the presence of animals and human activity. Some "contaminants" may be harmful. Others, such as iron and sulfur, are not harmful. Public water systems treat water to remove contaminants, if any are present.

In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and the State of Vermont. These regulations limit the amount of various contaminants:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the past year. It also includes the date and results of any contaminants that we detected within the past five years if tested less than once a year. The presence of these contaminants in the water does not necessarily show that the water poses a health risk.

Terms and abbreviations - In this table you may find terms you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Maximum Contamination Level Goal (MCLG): The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contamination Level (MCL): The "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of disinfectants in controlling microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. Addition of a disinfectant may help control microbial contaminants.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

90th Percentile: Ninety percent of the samples are below the action level. (Nine of ten sites sampled were at or below this level.)

Treatment Technique (TT): A process aimed to reduce the level of a contaminant in drinking water.

Parts per million (ppm) or Milligrams per liter (mg/l): (one penny in ten thousand dollars.)

Parts per billion (ppb) or Micrograms per liter (µg/l): (one penny in ten million dollars.)

Picocuries per liter (pCi/L): a measure of radioactivity in water.

Nephelometric Turbidity Unit (NTU): NTU is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Running Annual Average (RAA): The average of 4 consecutive quarters (when on quarterly monitoring); values in table represent the highest RAA for the year.

Detected Contaminants MONTPELIER WATER SYSTEM

Microbiological	Result		MCL			MCLG	Typical Source
No Results were Detected in Calendar Year 2016.							
Disinfection Residual	RAA	Range	Unit	MRDL	MRDLG	Typical Source	
Chlorine	0.816	0.070-1.510	Mg/l	4.0	4.0	Water additive to control microbes.	
Chemical Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
FLUORIDE	06/06/2016	0.8	0.7-0.8	Ppm	4.0	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
IRON	4/17/2014	0.036	.036-.036	ppm			Naturally occurring in groundwater.
NITRATE	01/20/2016	0.05	0.05-0.05	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Combined Radium	4/05/2012	1.19	1.19-1.19	pCi/L	5	0	Erosion of natural deposits
Radium-228	04/05/2012	1.19	1.19-1.19	pCi/L	5	0	Erosion of natural deposits
Lead and Copper	Date	90 TH Percentile	Range	Unit	AL*	Sites Over AL	Typical Source
COPPER	2016	0.61	0-0.92	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2016	3	0-19	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

*The lead and copper AL (Action Level) exceedance is based on the 90th percentile concentration, not the highest detected result.

Disinfection By-Products	Monitoring Period	LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2016	11	3.3-10.9	ppb	60	0	By-product of drinking water disinfection
TOTAL TRIHALOMETHANES (TTHM)	2016	19	12.1-30.1	ppb	80	0	By-product of drinking water chlorination

Violation(s) that occurred during the year

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. The table below lists any drinking water violations we incurred during 2010. A failure to perform required monitoring means we cannot be sure of the quality of our water during that time.

Type	Category	Analyte	Compliance Period
No Violations Occurred in Calendar Year 2016			

Revised Total Coliform Rule (RTCR) TT Violations: No RTCR TT Violations in Calendar Year 2016.

Level 1 Assessment: No Level 1 Assessment was required.

Level 2 Assessment: No Level 2 Assessment was required.

Health Information Regarding Drinking Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1.800.426.4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Montpelier Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Public Notice - Permit to Operate Issued April 17, 2013: The Water System is required to notify all users of the following compliance schedule contained in the Permit to Operate issued by the State of Vermont Agency of Natural Resources:

1. On or before August 1, 2014, the Permittee shall either provide for filtration and disinfection to those service connections currently being served untreated water from the City of Montpelier's raw water transmission line or physically disconnect those service connections from the raw water transmission line.
2. On or before October 1, 2014, the Permittee shall perform a comprehensive hydraulic analysis of the distribution system and provide an engineer's report with a list of recommended improvements prioritized in order of public health risk, necessity of improvement based on the technical requirements of the Rule, and submit an improvements report, plan and implementation schedule to the Secretary for review.

Public Notice – Uncorrected Significant Deficiencies: The system is required to inform the public of any significant deficiencies identified during a sanitary survey conducted by the Water Supply Division that have not yet been corrected. For more information, please refer to the schedule for compliance in the system's Operating Permit.

Date Identified	Deficiency	Facility
07/01/2008	Inadequate contact time for disinfection	Treatment Plant I

To learn more about your drinking water, please attend any of the City's scheduled Water Board meetings. To find out the exact date and time of the next meeting, please call the City Manager's Office at 223-9502 or visit the City's website at www.montpelier-vt.org.



Photo credit: Ethan C Lincoln

Landlords, please share this information with your tenants.

Additional copies of this report are available at the City Clerk/Treasurer's Office, 39 Main Street, Montpelier, and on the City's website: <http://www.montpelier-vt.org/DocumentCenter/View/3073>